

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Ringgold Water System has Levels of Disinfection Byproducts (DBPs)

Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to monitor your drinking water for the presence of disinfection byproducts (DBPs) on a quarterly basis. The DBPs test results from the last four (4) quarters that ended on 6/30/2020 show that our system exceeds the standards, or maximum contaminant level (MCL) for haloacetic acids (HAA5). MCL for HAA5 is calculated based on locational running annual averages (LRAA) of samples collected from the last four (4) quarters. The LRAA of HAA5 at 21 Hackett St. is at 0.076 mg/L. This value exceeds the respective MCLs for HAA5 (location) of 0.060 mg/L.

What should I do?

Currently, no alternative source of water is necessary. However, if you have any specific health concerns consult your doctor.

What does this mean?

This is not an emergency. If it had been, you would have been notified immediately. Some people who drink water containing HAA5 in excess of the MCL over many years may have an increased risk of getting cancer.

What Happened? What is being done?

When disinfectants are used in the treatment of drinking water, disinfectants react with naturally occurring organic and inorganic matter present in water to form DBPs. We are taking/have taken the following corrective actions: Increased flushing in the affected area and adjusting treatment technique.

We anticipate resolving the problem before the next testing cycle. If you have any questions, please contact City Hall at 706-935-3061 or 150 Tennessee street Ringgold Ga. 30736

**ATTENTION: PWS Operator/Responsible Party**

Tier 2 public notice (PN) must be provided as soon as practical, but no later than 30 days after you learn of the violation (141.203(b)). The PN must remain in place for as long as the violation or situation persists, but in no case for less than seven days. The PN must be repeated every three months as long as the violation or situation persists.

Community systems must use one of the following methods of delivery (141.203(c)(1)):

- Hand or direct delivery
- Mail, as a separate notice or included with the bill

Non-community systems must use one of the following methods of delivery (141.203(c)(2)):

- Posting in conspicuous locations
- Hand delivery
- Mail

In addition, both community and non-community systems must use another method reasonably calculated to reach others if they would not be reached by the first method (141.203(c)). Such methods could include newspapers, email, or delivery to community organizations. If you post the notice, it must remain posted until the violation is resolved. If the violation has been resolved, you must post the notice for at least one week (141.203(b)). If you mail, post, or hand deliver, print your notice on letterhead, if available.

**Corrective Actions**

In your notice, describe corrective actions you took or are taking. This could include information stating that you have since taken or are in the process of taking the required samples.

**After Issuing the Notice**

Within ten days after issuing the notice, you must send to EPA a copy of each type of notice, along with a certification (see example below) that you have met all the public notice requirements. Mail copies to:

PN RULE MANAGER  
US EPA REGION 8  
PUBLIC WATER SYSTEM PROGRAM - 8P-W-DW  
1595 Wynkoop Street  
DENVER CO 80202-2466

Or, you can fax a copy to **1-(877) 876-9101**.

**Certification of Public Notification**

I \_\_\_\_\_ certify that the attached public notification was issued  
(PWS Operator/Responsible Party)

from \_\_\_\_\_ to \_\_\_\_\_  
(Date) (Date)

The attached notice was issued by \_\_\_\_\_  
(Method of delivery)

Signature \_\_\_\_\_ Date \_\_\_\_\_